



## Are you sure your UST is in Compliance?

### COMPLETE THE CHECKLIST

- TANK REGISTRATION** – Registration is required to be posted on site, displaying all pertinent and current information
- A/B OPERATOR** – UST Operator Certificate.

#### DAILY

- DAILY ALARM LOG** – A log of visual alarm inspection must be kept.

#### WEEKLY

- WEEKLY SENSOR STATUS REPORTS** – Sensor Status reports must be kept for a period no less than 2 years.
- \*10-DAY RECONCILIATION** - Inventory must be record twice daily and reconciled on a rotation of 10 days. \* Retail sites only.

#### MONTHLY

- WALKTHROUGH INSPECTION**  
UST/AST Equipment must be inspected for operation and a record kept for a period no less than 5 years.

#### YEARLY

- 1YR**  **Line Leak Detector** – Once every year.
- Tank Monitor Certification** - Every year.
- 2YR**  **Functionality Test** – Every 2 years. NYC Fire Department & Nassau County Health Department
- 3YR**  **Spill Bucket Testing** - Every 3 years.
- Testing of Sumps & under Dispenser Containment Systems** - Every 3 years.
- Overfill Prevention Equipment Inspections** - Every 3 years.
- 5+YR**  **Tank** - Every 5-10 years  
(County Dependand, exceptions apply)

**TESTS MUST BE COMPLETED NO LATER THAN **OCTOBER 13, 2018****

Missing a single item on this checklist could result in thousands of dollars in penalties. Let Henrich's Environmental Compliance Services team provide you with peace of mind.

**WHERE YOU NEED US,  
WHEN YOU NEED US.**